
Walraven Yeti® 335 Frame Set

for Rooftop Installations

(10415)





6768 5 502



Features and benefits

- complete set for supporting installation appliances on flat roofs
- suitable for wide range of commonly used airco's, ventilation units, etc.
- with non-slip anti-vibration mat
- predefined load capacity: calculation not necessary
- surface protection:
 - product is part of the Walraven BIS UltraProtect® 1000 system
 - suitable for in- and outdoor applications
 - stands min. 1,000 hours salt spray test (max. 5% red rust) according to ISO 9227
- noise reduction according to DIN EN ISO 10140-1 and DIN EN ISO 10140-3 up to 31 dB(A)
- sets meet the requirements of DIN 18531-1
- UV-resistance according to EN ISO 16474-3:2014-02 - certified by ITB
- Part No. 67685501: consisting of:
 - 4 x BIS Yeti® 335 including non-slip anti-vibration mat (made of rubber)
 - 2 x 1.5 m BIS RapidStrut® Fixing Rail DS 5 (BUP1000), pre-assembled with vertical legs of 0.5 m on both sides, ready to just plug in the BIS Yeti® 335
 - 2 x 1 m BIS RapidStrut[®] Fixing Rail DS 5 (BUP1000), as a cross-connection to the frame. Connecting elements are already pre-installed on the frame
 - all connecting elements, rail end caps and bolts are included and most are pre-assembled
- Part No. 67685502: consisting of:
 - 6 x BIS Yeti® 335 including non-slip anti-vibration mat (made of rubber)
 - 2 x 2 m and 4 x 1.5 m pre-cutted BIS

- device can't be heavier than 150 kg
- top of device can't be higher than 1.2 m over the roof level
- mouldings made of WPC, a composite of recycled plastic and wood fibre





ITB No.



1762-001-19

IIB No. LZM00-02259





Walraven Yeti® 335 Frame Set

for Rooftop Installations

(10415)





6768 5 502



- 6 x 0.5 m BIS RapidStrut[®] Fixing Rail DS 5 (BUP1000), for use as vertical legs with pre-assembled connecting elements
- all connecting elements, rail end caps and bolts are included and most are pre-assembled

Part No.	Model	Pack 1
67685501	BIS Yeti® 335 for 1 installation appliance	1
67685502	BIS Yeti® 335 for 2 installation appliances	1

Before mounting, the roof load capacity has to be confirmed by a structural engineer. If changes to the mounting parameters is necessary then please contact Walraven Technical Department.









1762-001-19

ITB No. LZM00-02259

